

PAUL SCHERRER INSTITUT




David Reinhard:: Technical Building Infrastructure :: Paul Scherrer Institut

# Energy optimisations Implemented at accelerators and infrastructure at PSI

ESSR Grenoble, 29.9.2022

## Research at large facilities



Synchrotron  
Light Source  
SLS



Spallation  
Neutron  
Source  
SINQ



Muon Source  
 $\mu$ S



Free Electron  
Laser  
SwissFEL


# Key Figures

PSI funds (global budget)	300	MCHF
External funding	100	MCHF
Staff (heads)	2200	
• Externally financed	700	
• Doctoral students	310	
• Apprentices	100	
External users: people / visits	1500* / 2500*	per year
Number of scientific publications	1300 (17 % of which high impact)	per year
PSI employees with teaching duties at both ETH and universities	100	
Patient visits (proton therapy treatment)	5800	per year

\*corona-related decrease -50% appr.



# PSI`s Energy consumption (2021)



Standort	Datenpunktbeschreibung	Summe Einheit
WEHA	HIPA Energie gesamt [MWh]	76'915.093 MWh
OSFA SwissFEL	SwissFEL Energie gesamt [MWh]	17'398.735 MWh
WSLA SLS	SLS Energie gesamt [MWh]	22'599.563 MWh
WTSD	PROSCAN Energie gesamt [MWh]	5'081.991 MWh
WSHA Sultan	SULTAN Energie gesamt [MWh]	4'398.555 MWh
OEEA PANDA	PANDA Energie gesamt [MWh]	17.899 MWh
PSI West	PSI West Rest Energie [MWh]	3'758.539 MWh
PSI Ost	PSI Ost Energie (Büro, Labor und Infrastruktur) [MWh]	14'050.223 MWh

Total Power Consumption: 143 GWh

Total heat consumption: 5.7 GWh

# Efficiency Measures driven by PSI Energy Mission and Federal Energy Law

## **PSI Energy Mission Statement**

- PSI institute supports the role model function for efficient use of energy as a member of the Swiss government initiative "Exemplary Energy and Climate"
- During planning, construction, operation and renovation the aspect of energy efficiency is considered as a general guideline.
- Renovation programs at the accelerator facilities enable older components to be replaced with new, efficient and energy-optimised parts. Aspects of energy efficiency should serve as a general guideline for refurbishments, modernisations and replacement equipment.
- For new components, facilities and upgrade projects (e.g. SLS 2.0), particular attention is paid to energy efficiency (e.g. heat recovery, power electronics, magnets, high-frequency components).
- When planning new research facilities, a targeted energy minimisation and optimisation process should be carried out, preferably with the involvement of specialists.
- When procuring equipment, the most efficient options are generally preferred in terms of a life-cycle evaluation.

## **Legal Aspect: Large consumers are obliged to settle commitments (energy saving target) with Energy Agency**

- Major consumers including end users with a heat consumption of more than 5 gigawatt hours (GWh) or an electricity consumption of more than 0.5 GWh per year and per consumption site – hence, PSI also meets this definition. Special legal requirements apply to these businesses, private companies and public institutions.
- Based on the cantonal Energy Act, the canton of Aargau enforces Grossverbraucher-Bestimmungen to increase energy efficiency in companies. In order to meet the requirements of the Major Consumer Article, PSI concluded a universal target agreement with the Energy Agency of the Swiss Private Sector (EnAW) back in 2013, and it now reports annually on the achievement of the target path.

# Results of Energy Efficiency Measures at PSI (2013-2020)

**Number of measures and projects since 2013:**

**Yearly saving of el. energy:**

**Yearly saving of heat consumption:**

**Total yearly investments (average in 7 years):**

**Total yearly savings:**

**Total fundings awarded:**

**Total yearly refund of energy taxes:**

**75 (24 Heat; 61 Power)**

**7.4 GWh (-6%)**

**5.2 GWh (-43%)**


**1.2 Mio CHF**

**1 Mio CHF**

**3.6 Mio CHF (27 Projects)**


**2 Mio CHF**

Yearly Reduction of Energy Consumption [MWh]



**yearly saving of heat consumption: 5.2GWh (-43%)**

Yearly Reduction of Energy Consumption [MWh]



**yearly saving of el. energy:**

**7.4GWh (-6%)**



# Example 1, «Cryogenics» Replacement of HE-Compressors

- Two old but reliable piston compressors (cryogenic HE-Cycle in the filed of HIPA/SINQ) where replaced by 3 screw compressors
- Screw Compressors are more efficient and suited for continuous operation
- 270+570kW reduced to 160+500kW @ same boundary conditions, 6700 OH
- Yearly saving of 1.33GWh (appr. 1% of PSI consumption)



**Piston Compressors**



**Screw compressors with oil removal system**

# Example 1, «Cryogenics» Replacement of HE-Compressors



## Side effects:

- Standardised components allow reduction of spare parts
- More space through optimised architectural layout
- Lower vibration (SLS)



## Server Virtualisation (2009-2015)

- 1 server with virtualisation required 450W
- It replaces 35 conventional servers each consuming 200W
- Efficiency Increase of Factor 15!
- 550 Server 200W to 15 virtual 450W, Total Saving: 900MWh/a (45% from 2013)



# Example 3, «Operations», Sleep Mode Tool (HIPA+Proscan)





Figure 8: Distribution of 4 GWh HIPA Saving Potential.



- The Facility contains 370 power consuming magnetic elements.
- In case of an outage the respective beamline shall be switched of since there is no use.
- The Sleep software provide the operators the possibility to switch on/off (Standby) various beamlines with a single click of a button. (signalisation in case of outages with no beam longer than 30 minutes).
- The amount of energy is saved and reported.
- The saving is vise versa with the reliability

# Example 3, «Operations», Sleep Mode Tool (HIPA+Proscan)

SLEEP							
Beamline	Status	Beam Current	In Standby for	Currently Saved	Saved This Year	Control Switch	Notifications
IW2	ON	1705.8 $\mu$ A	0 d 0 h 0 m 0 s	0.0000 MWh	105.13 MWh	STANDBY ON	
IP2	ON	29.2 $\mu$ A	0 d 0 h 0 m 0 s	0.0000 MWh	253.39 MWh	STANDBY ON	
PK1	ON	1700.4 $\mu$ A	0 d 0 h 0 m 0 s	0.0000 MWh	139.42 MWh	STANDBY ON	
PK2	ON	1691.2 $\mu$ A	0 d 0 h 0 m 0 s	0.0000 MWh	122.61 MWh	STANDBY ON	
SINO	ON	1176.8 $\mu$ A	0 d 0 h 0 m 0 s	0.0000 MWh	2027.03 MWh	STANDBY ON	
UCN	ON	0.0 $\mu$ A	0 d 0 h 0 m 0 s	0.0000 MWh	198.94 MWh	STANDBY ON	Dismiss Notification
Total Power		1.837 MW		Total Savings		2846.5 MWh	

HIPA sleep overview beamlines current, status and savings

SLEEP - Master Control									
Section	Status			Power		Energy saved		No Activity	
	Wake up	Asleep	Go to sleep	Actual	Before sleep	Last time	This year		
Optis2	Wake up	Asleep	Go to sleep	7 d 1 h 44 m 13 s	0.2 kW	5.2 kW	733 kWh	28769 kWh	Warning
Gantry1	Wake up	Asleep	Go to sleep	46 d 12 h 30 m 21 s	0.3 kW	7.1 kW	6007 kWh	96621 kWh	
Gantry2	Wake up	Awake	Go to sleep	0 d 0 h 0 m 0 s	41.9 kW	41.8 kW	3683 kWh	195910 kWh	
Gantry3	Wake up	Awake	Go to sleep	0 d 0 h 0 m 0 s	8.0 kW	8.1 kW	690 kWh	8174 kWh	
QMA6-AMA3	G2 or G3 or O2	Awake	G2 and G3 and O2	0 d 0 h 0 m 0 s	8.3 kW	8.2 kW	704 kWh	6153 kWh	
				Total saved this year				335626 kWh	

sleep Proscan overview

**SLEEP - Gantry 2**

Wake up Awake

Go to sleep

Actual power 41.9 kW

Before sleep 41.8 kW

Hours

2019: 182'417 kWh  
2020: 195'910 kWh

+13'493 kWh  
+7.4%

**Details - Gantry 2 (Section B, F)**

Magnet	Voltage (V)	Current (A)	Power (W)
QMB1	-17.0	-41.1	697
QMB2	14.8	36.5	541
QMB3	-12.7	-30.5	387
QMB4	21.9	52.4	1148
QMB5	-11.7	-27.6	325
QMF1	-10.0	-37.4	373
QMF2	11.1	42.0	464
QMF3	-10.1	-37.3	377
QMF4	13.7	51.2	700
QMF6	14.3	53.7	767
QMF7	-11.2	-41.4	462
AMF1	64.7	109.5	7084
AMF2	65.6	109.4	7178
AMF3	83.7	251.5	21062

Power: Actual 41.9 kW, Asleep for 0 d 0 h 0 m 0 s

Before asleep 41.8 kW, Saved last time 3682.6 kWh

Admin... Graphs... Saved this year 195910 kWh

sleep Proscan detail view Gantry 2

*Personal note: Trivial but generic in various systems and applications. Observe and switch off what is not needed!*



# Example 4, «Campus Infrastructure», high temp. water loop

## Two Laboratories

- “OIPA” (Center for Radiopharmaceutical Sciences (CRS) to treat cancer)
  - “OHLA” (HOTLAB laboratory to handle large quantities of radioactive materials)
- With a total of 100`000m<sup>3</sup>/h air exchange require humidification



Hot Lab

- A high temperature loop of a standby emergency heating unit is used to feed the steam generators.



Oil storage tanks



Heating boilers 30MW for backup 80MW district heating system)




Steam generator



Steam injection

# Example 4, «Campus Infrastructure», high temp. water loop



- Step 1: Reduction of standby losses (standby emergency kept with conceptual adaptations)
- Step 2: Reduction of Setpoint rel. humidity (less comfort)
- Yearly Savings: 65`000l (650MWh)
- Future Step 3: Switch to low temperature humidification system (high investment in conjunction with general refurbishment of ventilation unit)

## LED Lightning WEHA, WNLA und WNHA (HIPA/SINQ)

- Yearly saving of 300MWh / 30kFr at more than double light intensity (300Lux)!



- Daylight-dependent light control
- Better color rendering
- Lifetime factor 5
- Less than 50% of energy consumption compared to former gas discharge lights




# Example 6, «Air Conditioning», Optimisation of Cooling System

Starting point: Energy assessment of laboratory «OIPA»


## Heat Consumption

Thermischer Energiebedarf	MWh/a	%
Heizverbrauch "Befeuchtung"	174	9%
Heizverbrauch Anteil "Speicherverluste (50%)"	243	12%
Lüftungsanlage (abz. WRG Anteil)	674	33%
Heizkörper (ca. 20% von Lüftung)	134	7%
Nachwärmer Lüftung	141	7%
WRG Anteil Lüftung (50%)	674	33%
Total	2'040	100%



## Power Consumption


Elektrischer Energiebedarf	MWh/a	%
Kältemaschinen	262	23%
Ventilatoren Lüftungsanlagen	193	17%
Ventilator Hauptfortluft OIPA	439	38%
Umwälzpumpen	67	6%
Wasserewärmer	39	3%
Sonstiger Hausbedarf	141	12%
Total	1'141	100%



- Reduced to 80 MWh (EER 1.3 → ESEER 3.3, Seasonal CW Temp., Freecooling, inefficient HRC eliminated )
- Circulation pumps reduced from 67 to 19MWh

# Example 6, «Air Conditioning», Optimisation of Cooling System

## Impressions



Former Ciller consisting of 2 units, year 1984



Assembly of dry cooling unit on the building roof



Cooling water distributor including emergency connection




New chillers including buffer tank

# Example 7, «Air Conditioning», Humidity Control


## Interim storage facility for low-level radioactive waste

- low air humidity to prevent corrosion
- rel. high air exchange rate



## Optimisation:


- Dehumidifying system with combined heat pump- adsorption drying system with a high efficiency and effectivity
- ¼ Consumption compared to basic model, payback time 15 years






# Example 8, «Heating System», Heat Recovery

Original System




Today`s System



Radiatoren:  
55/35 °C  
Lüftungen:  
55/35 °C


Future System



Radiatoren:  
45/25 °C  
Lüftungen:  
35/20 °C

## Measures Executed 2012-2015

- Separation of heating water cycle (Refuna / PSI)
- Integration of heat sources (high temperature cooling loops)
- Temperature decrease:
  - Modification of building heating stations
  - Replacement of Radiators
  - Replacement of ventilation heaters



Existing heat exchanger with  $dT_m=22K$




New heat exchanger with  $dT_m=5K$

Original Design Temperature 50...80° C  
New Design Temperature 35/20° C

New Design:  
45/30° C


Original Design:  
70/50° C



1500 Radiators replaced

## Presentation ESSRI 2015

# Example 8, «Heating System», Heat Recovery



Energy monitoring tool

Successful project since very effective and economic measure!

Payback reached: yearly benefit from now: 450kCHF

Total heat recovered since 2013 [MWh]		58453
District Heat price [CHF/MWh]		63
Savings since 2013 [CHF]		3'682'535.60
Total Cost [CHF]		3'785'000.00
break-even point in year		2022
payback time [year]		9

## «and much more...»




- Replacement of power supplies HIPA with higher efficiency and stand by mode
- Replacement of transformers
- Renewal of building heating systems (pumps, control systems)
- Energy Assessments and Checks for Laboratories (cleanrooms!)
- Cooling optimisation in central datacenters
- Guidelines for technical building Infrastructure
- Energy monitoring with monthly reports



# Outlook of future energy saving measures

Today's identified midterm potentials:


PV plants on PSI roofs	GWh	6
Optimisation Cooling Circuits and Pumps HIPA	GWh	2.5
Continuous Improvement building technical Infrastructure (10 years period)	GWh	1.3
Optimisation Cryogenic Cooling System of Superconducting Test Facility "Sultan"	GWh	2.75
SLS 2.0 Overall Optimisations	GWh	5
<b>Total Power Savings Potential</b>	<b>GWh</b>	<b>17.55</b>
in % of today`s consumption		12%



# Upgrade SLS 2.0

## Upgrade of SLS → SLS 2.0

- Brilliance up to 1,000 times higher on certain beamlines.
- Electron energy from 2.4 GeV to 2.7 GeV
- Maximum photon energy from 45 keV to 80 keV
- Beam quality Up to 40 times better than before.
- Inner diameter of the beam pipe decrease from 64 down to 18 millimeters
- Number of magnets increase from 388 to 1`007 (Replacement)




### Energy Efficiency Potentials through:

- "New" technologies & developments
- Optimizing infrastructure concepts
- Adapting to the new boundary conditions,

## Project SLS 2.0



An upgrade of strategic importance for the Paul Scherrer Institute




# Reduction Potentials SLS 2.0

## Energy Optimisation Potentials

### Before / After Comparison

**Table 1:** Left Column, Current Power Consumption theoretical (measured: 22.6GWh); Right Column, Expected Power Consumption 17GWh (Minimum, if all Potentials realised: 25%), excl. Power Consumption for potential Heat Production for Campus.



### Result:


- Increase in output/utility (beam quality approx. factor 40)  
*with a simultaneous*
- Reduction of -25% energy consumption



# Reduction Potentials SLS 2.0


## Main Optimisations (RF Amplifiers and Magnets)

- Use of permanent magnets for the deflection magnets (new development!)



Elektromagnetischer Dipol, bestehend aus:  
 -- Zwei Jochteilen  
 -- Zwei Spulen


Dipol mit Permanentmagneten, bestehend aus:  
 -- Elf Jochteilen  
 -- 98 Permanentmagneten  
 -- 16 NiFe-Bleichen



$$P_{in} = 430 \text{ kW}$$

$$P_{in} = 0 \text{ kW}$$

- Efficiency increase by replacement of all 4 conventional tube type amplifiers by solid-state amplifiers



$$\eta = 44\%$$



Fig.12: Solid state amplifier station


$$\eta = 56 \dots 58\%$$

# Reduction Potentials SLS 2.0


## Main Optimisations (Cooling and PV)

- Optimization of the cooling water production and distribution (VDC, Reduction of  $\Delta p$ , increase  $\Delta T$ )

Situation Heute



Optimierung durch FU



- Optional: Use of chillers which can be used as heat pumps in winter (heat recovery, 1.8MW, 2.5 GWh)
- Optional: photovoltaic electricity production on the building roof
  - Due to the limited weight, only light and flexible solar panels can be considered.
  - Roof Area 12`000m<sup>2</sup>, peak power of about 1 to 1.5 MW, annual energy of about 1 to 1.5 GWh. This would cover about 5 % of the annual energy demand of SLS 2.0.





## Energy Mission PSI

- “Wherever feasible, electricity and heat consumption are reduced to a minimum using long-term concepts and ongoing operational optimisations.”
- <https://www.psi.ch/en/about/psi-energy-concept>

